

Suite 1, 1351 Estevan Road    Tel 250 716 3336  
Nanaimo BC    Fax 250 716 3339  
Canada V9S 3Y3

**McElhanney**

DATE	DESTINATION EMAIL	NO OF PAGES (INCL THIS PAGE)	FILE
July 4, 2024	n/a	3	2231-35337-01
TO	FROM		
ALL DOCUMENT HOLDERS	S. O'Connor		
COMPANY	ORIGINALS TO BE:		
	<input type="checkbox"/> Filed <input type="checkbox"/> Mailed <input type="checkbox"/> Couriered		
CITY	OTHER (SPECIFY)		

---

**MESSAGE**

District of Tofino  
Tofino Ball Field Improvements

Attached, please find Addendum # 1 for the above noted project.

Electronic PDF includes:

01 page(s) – Cover  
02 page(s) – Addendum #1

McElhanney Ltd.

### Addendum # 1

The following information and corrections are added to the Tender Documents for this project:

#### 1. Questions & Answers:

1. Question: We would like to request a 1-week extension to the tender period.

**Answer: Unfortunately, the District can't extend the closing date of July 8, 2024.**

2. Question: Is Contractor required to process timber for District use?


**Answer: No, the Contractor is responsible for disposal of timber. Payment for all clearing and grubbing includes removal and disposal of all branches, stumps, timbers, and vegetation remains.**

3. Question: For the Ball Diamond Infield Mix Product we have been unable to find local supplier that can provide exact material specified. Will a locally supplied product that is consistent with the existing infield surface be acceptable?

**Answer: Yes, a locally sourced product will be acceptable. Contractor to provide sieves to confirm that the alternate product is consistent with existing material prior to approval.**

4. Question: Based on site visit the proposed gravel access appears to be in conflict with new parking lot. Is this gravel access location going to be revised prior to construction?

**Answer: Yes, the daycare parking layout has changed which will require an adjustment to gravel access location. It is anticipated that the access location and maintenance gate will be relocated as shown below in red.**



---

**Addendum # 1**

---

5. Question: For bonding requirements on electronic submissions will an ink scan suffice, or will the tender submittal require a digital bond?

**Answer: Ink scan or digital bond will be acceptable.**

6. Question: What is the anticipated award date?

**Answer: The District is expecting to award the contract by July 12, 2024 provided the project is within District budget.**

7. Question: Can a disposal site be provided by the District to support this project?

**Answer: The District has a disposal site ("Stump Dump") that can be used for the project. The disposal site can receive materials from the clearing & grubbing, rock removal, and unsuitable soil material removal. The disposal site cannot receive removal materials such as concrete, fencing, posts, etc.**

**District staff will provide direction on site dumping locations for different materials prior to construction (i.e. expected dumping location of clearing debris vs soils vs rock).**

**If the Contractor elects to make use of the disposal site, the Contractor will be responsible for maintenance of site access and disposal site during use.**

**The disposal site is located approximately here:**

**<https://www.google.ca/maps/dir//49.093152,-125.8483846/@49.093951,-125.8478327,1464m/data=!3m1!1e3!4m2!4m1!3e0>**

